CYLINDER VALVE DATA SHEET

Tag No. **MAW14AA210
Mfr. Serial No. 18CY075A/B

1	2	3	4	5
	1			Location indoor
	2			Service HP TURBINE INLET B WELD COOLING LINE STOP VALVE
	3			Haz. area class.
	4			Ambient temp. min. 22 °C max. 35 °C
	5	1		Allowable sound pressure level — dB(A)
	6	1		Pipe identification No. —
	7	1		DN 65 / 65 Sch /
	8			Pipe material /
	9			Pipe insulation —
	10			
	11			Pipe connection BUTT WELD END
	12			Process fluid STEAM
	13			Upstream condition □liquid ■vapour □gas
	14			Des.press. 61.0 bar(g) Des.temp. 568 °C Backpress. NO
	15			Min. / Norm. / Max. / Unit
	16	1		Flow rate — / — / — / m3/h
	17	1		Inlet press. P1 — / — / — / bar(g)
	18	1		Outlet press. P2 — / — / — / bar(g)
	19	1		Temperature T1 — / — / — / °C
	20			
	21			
	22			
	23			
	24			
	25			
	26			
	27	1		Shutoff press. P1 61.0 P2 — bar(g)
	28			Air supply min. 6 max. 6 bar(g)
	29			Power failure pos. ■open □closed □hold
	30			
	31	1		Calc.max.flow coef.Cv — Calc.nor.flow.coef. —
	32	1		Calc.min.flow coef. Cv —
	33			Selected flow coef. Cv 60
	34	1		Predicted sound pressure level — dB(A)
	35			MFR. NAKAKITA SEISAKUSHO CO.,LTD. Model NS650ELOL
	36	1		Body type □Gate ■Globe □Ball □Butterfly
	37			Flow direction ■FTO □FTC □MIXING □DIVIDING □RETURN
	38			Pressure rating 2500#
	39			Nominal size DN65
	40			End conn. □flgd. □s.welded ■b.welded □thd.
	41			BW
	42			End extensions
	43			Bonnet style □standard □fin ■long □extension □bellows
	44			Mounting method Refer to drawing
	45			Body/bonnet matl. A217M WC9
	46			Trim ■p-port □labyrinth □cage □pilot □low noise
	47			Characteristic ■quick opening
	48			Plug/stem matl. SUS316 / SUS316
	49			Guide/seat matl. SUS316 / STELLITE
	50			
	51			Seat style ■metal touch □soft touch
	52			Trim coating S.STEEL/STELLITE
	53			
	54			Leakage specification JEAC3706 0ml/1min(WATER)
	55			Packing matl. P#6710+P#6616A
	56			gasket matl. V#8590ML

Section labels: PROCESS DATA RELEVANT FOR CONTROL VALVE SELECTION; Cv/SPL; VALVE BODY ASSEMBLY

1	2	3	4	5
	57		ACTUATOR	MFR. NAKAKITA SEISAKUSHO CO.,LTD. Model D400
	58			Pneumatic ■piston
	59	1		Style ■single acting (spring return)
	60			Act.area 1257cm2
	61			Reqd. travel/angle 20 mm
	62			Supply press. min. 6 max. 9 bar(g)
	63			Spring range
	64			Air consumption 61.1 ℓ(Nor.)/STROKE
	65			Air connection □Rc1/4 ■Rc3/8 □Rc1/2 □Rc3/4
	66			Other actuator
	67			
	68			■Handle
	69			
	70			
	71			
	72			
	73			
	74			
	75			
	76			
	77			
	78			
	79			
	80		POS. IND. SWITCH	MFR. Azbil Model VCL-5102
	81			Switch type ■mech. □proximity □pneum.
	82			Switching pos. ■closed □% travel ■open
	83			Switch acting ■make □break
	84			Reduction of haz. □intrin. Safe □explos.-proof ■non.
	85			Cable gland G 3/4 Qty 2
	86		SOLENOID VALVE	MFR. ASCO Model HTJ316G54MB
	87			Valve style □two way ■three way □four way
	88			De-energ.:control valve ■open □closed □lock
	89	1		IP rating IP65
	90			Air connection Rc 3/8 Port size Rc 3/8
	91			Electrical data AC220V50Hz
	92			Reduction of haz. □intrin. Safe □explos.-proof ■non.
	93			Cable gland G 1/2 Qty 1
	94		OTHERS	Articles FILTER REGULATOR Model AW40-03G-2-X2312A Qty 1
	95			Articles Model Qty
	96			Articles Model Qty
	97			Articles Model Qty
	98			Articles Model Qty
	99			Articles Model Qty
	100			Articles Model Qty
	101			Articles Model Qty
	102			Articles Model Qty
	103			Articles Model Qty
	104			Tubing/connection 37° SFJϕ10+BOOTS Matl. C3604
	105		SPECIAL REQUIREMENTS	Test certificate(s) ■ chem. and mech. test
	106			Test Press.(Assembly) ■water □air 91.5 bar(g)
	107			■ shell 647 bar(g) Mass. 410 kg
	108			Shut OffPress. 67.1 bar(g)
	109			Paint Color Silver /(Body) Silver /(Act.)
	110			Valve Speed(sec.) O→C ≦ 10 C→O ≦ 10
	111			□ High-temp spec. □ Low-temp spec. □ salt damage-proof spec.
	112			Rule

Remarks:

FILTER REGULATOR SET PRESS. : 6bar(g) [INLET PRESS. : 6~8bar(g)]

PLANT No.	TAG No.**	SERIAL No.
XIT05	50	A
XIT06	60	B

Rev.	Date	Name	Rev.	Date	Name		
1	10/22'18	Y.B.				Project	Dwg. Ref. No. 18CY074V ACELQ10HBDE
						Plant	Mat. Req. No.
						P.O.No.	Item No. Qty 1

Tanjung Jati B Expansion (Jawa-4) Coal Fired Steam Power Plant 2 x 1,000 MW
Strategic Spare Part List

Item No.	Equipment Tag Number (KKS) Level 0 (Total Plant)	Level 1 (System Code)			Level 2 (Equipment Code)			Level 3 (Component Code)			Equipment Name	Description of Spare Items	Supplier Name	Catalogue or Part Number	Qty per Unit	Current Unit Price	Total Amount	Lead Time for Delivery (Month)	Sketch	Cross Reference Drawing	Expected Frequency of replacement	Remarks
	G	F_0	$F_1F_2F_3$	F_N	A_1A_2	A_N	A_3	B_1B_2	B_N													
TJB5-SS-I&C-CV-097	5	0	LCJ	30	AA	220	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-098	5	0	LCJ	30	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-099	5	0	LCJ	30	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-100	5	0	LCJ	30	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-101	5	0	LCJ	30	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-102	5	0	LCJ	30	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-103	5	0	LCJ	30	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-104	5	0	LCJ	40	AA	220	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-105	5	0	LCJ	40	AA	220	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-106	5	0	LCJ	40	AA	220	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-107	5	0	LCJ	40	AA	220	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-108	5	0	LCJ	40	AA	220	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-109	5	0	LCJ	40	AA	220	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-110	5	0	LCJ	40	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-111	5	0	LCJ	40	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-112	5	0	LCJ	40	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-113	5	0	LCJ	40	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-114	5	0	LCJ	40	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-115	5	0	LCJ	40	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-116	5	0	LCJ	65	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-117	5	0	LCJ	65	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-118	5	0	LCJ	65	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-119	5	0	LCJ	65	AA	210	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-120	5	0	LCJ	65	AA	210	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-121	5	0	LCJ	65	AA	210	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-122	5	0	LCJ	61	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-123	5	0	LCJ	61	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-124	5	0	LCJ	61	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-125	5	0	LCJ	61	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-126	5	0	LCJ	61	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-127	5	0	LCJ	61	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-128	5	0	PGA	07	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-129	5	0	PGA	07	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-130	5	0	PGA	07	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-131	5	0	PGA	07	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-132	5	0	PGA	13	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-133	5	0	PGA	13	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-134	5	0	PGA	13	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-135	5	0	PGA	13	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-136	5	0	PGA	13	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-137	5	0	PGA	13	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-138	5	0	PGA	14	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-139	5	0	PGA	14	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-140	5	0	PGA	14	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-141	5	0	PGA	14	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-142	5	0	PGA	14	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-143	5	0	PGA	14	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-144	5	0	PGA	09	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-145	5	0	PGA	09	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-146	5	0	PGA	09	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-147	5	0	PGA	09	AA	205	-	-	-	ON-OFF Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-148	5	0	PGA	09	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-149	5	0	PGA	09	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-150	5	0	LBQ	50	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-151	5	0	LBQ	50	AA	210	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-152	5	0	LBQ	50	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-153	5	0	LBQ	50	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-154	5	0	LBQ	50	AA	210	-	-	-	Control Valve	PACKING RING	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	3 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-155	5	0	LBQ	50	AA	210	-	-	-	Control Valve	PACKING RING	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-156	5	0	MAW	03	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-157	5	0	MAW	03	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-158	5	0	MAW	03	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-159	5	0	MAW	03	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-160	5	0	MAW	03	AA	210	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-161	5	0	MAW	03	AA	210	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-162	5	0	MAW	03	AA	210	-	-	-	Control Valve	PACKING RING	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-163	5	0	MAW	03	AA	210	-	-	-	Control Valve	PACKING RING	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-164	5	0	MAW	18	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-165	5	0	MAW	18	AA	205	-	-	-	Control Valve	PACKING RING	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	4 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-166	5	0	GCK	10	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-167	5	0	GCK	10	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-168	5	0	GCK	10	AA	205	-	-	-	Control Valve	GASKET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-169	5	0	GCK	10	AA	205	-	-	-	Control Valve	SHIM	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-170	5	0	GCK	10	AA	205	-	-	-	Control Valve	WIPER	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	1 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-171	5	0	GCK	10	AA	205	-	-	-	Control Valve	PACKING SET	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-172	5	0	LCA	55	AA	-	-	-	-	Control Valve	Positioner with Position Transmitter for Control Valves	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	4 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-173	5	0	LCE	20	AA	-	-	-	-	ON-OFF Valve	Limit Switch for Pneumatic On-Off Valves	Nakakita Seisakusho	TJB56-L-1-OFF-C-00-H-LST-5683	4 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-174	5	0	MAW	10	AA	205	-	-	-	ON-OFF Valve	Solenoid Valve(WPT3827) for Pneumatic On-Off Valves	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-175	5	0	MAX	01	AA	202	-	-	-	ON-OFF Valve	Solenoid Valve(JJKHJ327) for Pneumatic On-Off Valves	Nakakita Seisakusho	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-176	5	0	LAB	02	AA	-	-	-	-	ON-OFF Valve	Solenoid Valve(HTJ316) for Pneumatic On-Off Valves	Nakakita Seisakusho	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-177	5	0	MAG	15	AA	-	-	-	-	ON-OFF Valve	Solenoid Valve(M15G) for Pneumatic On-Off Valves	Nippon Daiya Valve	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-178	5	0	LCA	55	AA	205	-	-	-	Control Valve	Filter Regulator(AW40-N06) for Control Valves	Fisher	TJB56-L-1-OFF-C-00-H-LST-5683	2 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-179	5	0	MAW	14	AA	210	-	-	-	ON-OFF Valve	Filter Regulator(AW40-03G) for On-Off Valve	Nakakita Seisakusho	TJB56-L-1-OFF-C-00-H-LST-5683	4 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5742	4 years	Common for both Unit5 & Unit 6
TJB5-SS-I&C-CV-180	5	0	LAB	05	AA	-	-	-	-	ON-OFF Valve	Filter Regulator(AW30-03G) for On-Off Valve	Nakakita Seisakusho	TJB56-L-1-OFF-C-00-H-LST-5683	4 pc	Later	Later	Later	TJB56-L-1-OFF-C-00-H-LST-5683	TJB56-L-1-OFF-C-CS-I-DAS-5741	4 years	Common for both Unit5 & Unit 6
TJB5-SS-