


NO	MARK DR CODE	DESCRIPTION	QTY	MATERIAL	WEIGHT (KGS)		REMARK (KKS)
					SINGLE	TOTAL	
16	TSL-100	WET ASH UNLOADER Q=100t/h	1	Q235-B	4850	4850	SOETEDA001
17	TJBS5-0706-03	DISCHARGE PIPE	1	Q235-B	1187	1187	
18	GB/15780-2000	BOLT-M6X70	4	GRADE 6	0.029	0.116	
19	GB/15780-2000	NUT-M6	4	GRADE 6	0.029	0.116	
20	GB95-85	WASHER-16	4	140HV	0.01	0.04	
21	GB/15780-2000	BOLT-M20X60	12	GRADE C	0.12	1.44	
22	GB/15780-2000	NUT-M20	12	GRADE 6	0.029	0.46	
23	GB93-87	WASHER-20	12	65Hh	0.01	0.12	
24	GB853-88	WASHER-20	24	Q235-B	0.017	0.41	

TOTAL WEIGHT: 5642 KG

TECHNICAL SPECIFICATION SHEET


WET ASH UNLOADER		ROTARY FEEDER	
TYPE	TSL-100	TYPE	TC-100
CAPACITY	100 t/h	CAPACITY	100 t/h
PRESSURE	0.4-0.6 MPa	SPECIFICATION	400X400 mm
WATER	15-25 t/h	REDUCER TYPE	R77MEBAX 100LB
REDUCER TYPE	R107MEBAX 180MLB POWER	POWER	3 Kw
ROTARY SPEED	35 r/min	ROTARY SPEED	32 r/min



- NOTE:
- THIS INSTALLATION DRAWING IS JUST FOR THE EQUIPMENTS OF UNIT 5. THIS EQUIPMENTS OF UNIT 6 WILL BE A MIRROR-IMAGE OF UNITS.
 - ALL DIMENSIONS ARE IN MM UNLESS NOTED OTHERWISE.
 - REGARDING THE LOCATION OF EQUIPMENT, PLEASE SEE THE GA & PIPING ARRANGEMENT DRAWING, TJB-56-L3-OFF-U5-EIE-M-DGA-0002, TJB-56-L3-OFF-U6-EIE-M-DGA-0003, TJB-56-L3-OFF-U6-EIE-M-DGA-0714, TJB-56-L3-OFF-U6-EIE-M-DGA-0715.
 - KKS CODE SHOWN IN THIS DRAWING IS APPLIED FOR UNIT 5 ONLY. WHEN THIS DRAWING IS UNSED FOR UNIT 6, THE FIRST TWO NUMBERS OF KKS CODE SHALL BE CHANGED FROM '50' TO '60'.

FOR CONSTRUCTION

BASIC PLAN



NO	DD/MM/YY	ISSUED FOR CONSTRUCTION	BY	DESIGN/DATE/APPD	REVISIONS AND RECORD OF ISSUE	YD	SAM	XZC	REMARK (KKS)
0	21/NOV/18	ISSUED FOR CONSTRUCTION							

OWNER: PT.Bhumi Jati Power

PROJECT TITLE: TANJUNG JATI B EXPANSION (JAWA-4) COAL FIRED STEAM POWER PLANT 2 x 1000 MW

OWNER'S ENGINEER: POYRY

EPC CONTRACTORS: Sumitomo Corporation, PT. Waas Mitra Engineering, AvantPower Japan Ltd.

PROJECT DRAWING NO.: TUB56-L3-OFF-C-EIE-M-DGA-0706

INSTALLATION DRAWING FOR WET ASH UNLOADER SYSTEM

APPD/ENGR	XZC	BY	YD	UNITS	VIEW
CHKD	SAM	DD/MM/YY	21/NOV/18	MM/M	ISOMETRIC

EPC LOT3 SUB-CONTRACTOR: BLACK & VEATCH

EPC LOT3 SUB-CONTRACTOR DRAWING NO.: TUB56-0706

WUXI HUADIAN

SHEET NO. 8 OF 1

REV. 0

Uncontrolled when printed or downloaded. Verify that this is the correct version before use. Reproduction of part or all the contents of the document is prohibited without written permission from PT. Bhumi Jati Power.