

13 SANITARY AERATION BLOWER MOTOR DATA SHEET

1. Name of motor	-	Sanitary aeration blower motor			
2. Manufacturer	-	SIEMENS CHINA			
3. Country of origin	-	CHINA			
4. Type/machine code	-	1LE0001-1CA13-3AA4			
5. Applied standard (characteristics)	-	IEC			
6. Ratings					
(1) Rated output	kW	7.5			
(2) Service factor	-	1			
(3) Number of pole	-	2			
(4) Rated speed	min ⁻¹	2930			
(5) Rated voltage	V	380			
(6) Number of phases		3			
(7) Rated frequency	Hz	50			
(8) Insulation class	-	F			
(9) Temperature rise	-	B			
(10) Rated duty		S1			
7. Service Conditions					
(1) Starting method	-	Directly			
(2) Direction of rotation (viewed from DE)	-	Clockwise			
(3) Reverse rotation (Yes / No)	-	No			
(4) Location (Indoor / Outdoor)		Indoor			
(5) Enclosure IP rating	-	IP54			
(a) Motor frame	-	IP54			
(b) Terminal boxes	-	IP54			
(6) Installation (Horizontal / Vertical)		Horizontal			
(7) Design ambient temperature	°C	-20~+ 40			
(8) Explosion proof (Required / Not required)		Not required			
(9) Noise level (at full-load condition)	dB (A)	66.0dB(A)			
Originator CHEC WATER	Identification number TJB56-GNA-E-DAS-0001	Rev. B	Date 31/MAR/19	Lang. En	Sheet 51/102

8. Characteristics		
(1) Current		
(a) Normal current	A	14.5
(b) No-load current	A	
(c) Starting current	A	108.75
(2) Torque		24.4NM
(a) Starting torque	%	56.12NM
(b) Maximum torque	%	70.76NM
(3) Slip at rated output		
(4) Efficiencies		
(a) At 100% load	%	88.1
(b) At 75% load	%	88.8
(c) At 50% load	%	
(d) At 25% load	%	
(5) Power factor		
(a) At rated load	%	89
(b) At starting load	%	
(6) GD2 coupled with driven equipment	kg-m ²	
(7) Starting time with driven equipment	s	
(8) Allowable number of starts		
(a) From cold condition per hour	-	
(b) From hot condition per hour	-	
(c) Minimum time between 2 starts (running state)	min	
(d) Minimum time between 2 starts (stop state)	min	
(9) Allowable locked-rotor time		
(a) At cold condition	s	
(b) At hot condition	s	

Originator CHEC WATER	Identification number TJB56-GNA-E-DAS-0001	Rev. B	Date 31/MAR/19	Lang. En	Sheet 52/102
--------------------------	---	-----------	-------------------	-------------	-----------------

9. Constructions		
(1) Stator winding connection (Wye / Delta)	-	Delta
(2) Type of bearing (DE / NDE)	-	6208-2Z-C3
(3) Lubricants		
(a) Recommended lubricant and brand name	-	
(b) Pouring method	-	
(c) Quantity of lubricant for initial filling	-	
(d) Recommended interval for recharging	-	
(e) Recharging quantity	-	
(f) Location of pouring	-	
(indicated in the outline drawing)		
(4) Bearing cooling water requirement (if required)		NA
(a) Quantity	m ³ /h	NA
(b) Inlet water temperature	°C	
(c) Required cooling water pressure	kPa	
(d) Type of cooling water	-	
(5) Water to air heat exchanger (if applied)		
(a) Quantity of cooling water	m ³ /h	NA
(b) Inlet water temperature	°C	NA
(c) Required cooling water pressure	kPa	NA
(d) Type of cooling water	-	NA
(6) Space heater (AC 220V 1 phase)	W	NA
(7) Weight	kg	92
10. Attached document numbers		
(1) Motor outline drawing	-	NA
(2) Terminal box drawings	-	NA
(a) For main power	-	NA
(b) For instruments	-	NA
(c) For space heater	-	NA

Originator CHEC WATER	Identification number TJB56-GNA-E-DAS-0001	Rev. B	Date 31/MAR/19	Lang. En	Sheet 53/102
--------------------------	---	-----------	-------------------	-------------	-----------------

(3) Current transformers (for MV motors only)		NA
(a) Characteristics curves	-	NA
(b) Outline drawing	-	NA
(4) Efficiency curves	-	NA
(5) Thermal capability curves		NA
(a) At cold condition	-	NA
(b) At hot condition	-	NA
(6) Starting and speed torque characteristics at 80%, 90% and 100% voltage	-	NA

CONFIDENTIAL

Originator CHEC WATER	Identification number TJB56-GNA-E-DAS-0001	Rev. B	Date 31/MAR/19	Lang. En	Sheet 54/102
--------------------------	---	-----------	-------------------	-------------	-----------------